



KARNATAKA GOVERNMENT
ZILLA PANCHAYAT, BENGALURU URBAN DISTRICT
OFFRICE OF THE TALUK HEALTH OFFICER, GENERAL HOSPITAL COMPOUND
ANEKAL. ANEKAL TALUK, BENGALURU URBAN DISTRICT
PHONE NO.: 080-29785533. Email ID: thoanekaltaluk@gmail.com

NO/THO/AKL/248/2022-23

Date: 03-12-2022

It is certified that an inspection team headed by Dr.RAVI C.R., Taluk Health Officer of Anekal Taluk Bangalore Urban District. Inspected the premises of ENDEAVOUR ACADEMY NO. 41, BUKKASAGARA VILLAGE, BANNERUGHATTA POST, ANEKAL TALUK BENGALURU URBAN-560105, ON 28/11/2022 and found that, the institution has safe drinking water facilities for the students and members the institution and is maintaining hygienic standards of sanitation in the campus, as per the norms prescribed. All the staff currently working at the institution are duly vaccinated till date against covid-19.

The above valid for a period of One Year.

Signature with Seal:

Name: Dr. RAVI C.R

Designation: Taluk Health Officer


ತಾಲ್ಲೂಕು ಆರೋಗ್ಯಾಧಿಕಾರಿಗಳು


ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಆನೇಕಲ್

ಛಂದೋದರು ನಗರ ಜಿಲ್ಲೆ

To,
PRINCIPAL
ENDEAVOUR ACADEMY
NO. 41, BUKKASAGARA VILLAGE,
BANNERUGHATTA POST,
ANEKAL TALUK BENGALURU-560105

For ENDEAVOUR ACADEMY


Secretary



PRINCIPAL


ENDEAVOUR ACADEMY

CBSE AFFILIATION No. 830980

No. 41, Bukkasagara Village,

Bannerghatta Post, Anekal Taluk,

Bangalore - 560 105. Tel : 080-29795002



GLOBAL ANALYTICAL LABORATORY

ISO 9001:2015

#33/2, Shop No 13, C R S Building, C Ramaiah Layout, Ramachandrapura Main Road,
Vidyaranyapura, Bangalore - 560 097 Mob 9686489581, 9353921722
E-mail: globaltesting2020@gmail.com



PHYSICAL & CHEMICAL ANALYSIS REPORT

Report No: GAL/06/3523	Report Date: 22.06.2023
Name: M/S ENDEAVOUR ACADEMY	Sample Collected On: 20.06.2023
Address: # 41, BUKKASAGARA VILLAGE	Sample Tested On: 20.06.2023
BANNERGHATTA ANEKAL TALUK, BENGALURU - 560083	Sample Particulars: RO - WATER
The water sample submitted by client and analyzed by us with the following results:	
SAMPLE DESCRIPTION: Colorless, Odorless, and Transparent Liquid	

TESTS (As per IS 10500:2012)	RESULTS	Maximum RO - LIMITS (In mg/l)	Maximum Acceptable Limits (In mg/l)	Protocol IS-3025	
Parameters					
1	Color, Hazen Units	<0.01	0.01	5	IS-3025/Part-4
2	Odor	Agreeable	Agreeable	Agreeable	IS-3025/Part-5
3	Turbidity, NTU	0.00	0.00	1	IS-3025/Part-10
4	PH Value	5.7	5.5 - 9	6.5 - 8.5	IS-3025/Part-11
5	Total Hardness as CaCO ₃ , mg/l	3	20	200	IS-3025/Part-21
6	Calcium as Ca, mg/l	1.2	6	75	IS-3025/Part-40
7	Magnesium as Mg, mg/l	0.34	1	30	IS-3025/Part-46
8	Chloride as Cl, mg/l	2.85	20	250	IS-3025/Part-32
9	Total Dissolved solids, mg/l	6	80	500	IS-3025/Part-16
10	Sulphate as SO ₄ , mg/l	0.00	0.00	200	IS-3025/Part-24
11	Nitrate as NO ₃ , mg/l	0.27	1	45	IS-3025/Part-34
12	Fluoride as F, mg/l	0.00	0.00	1.0	IS-3025/Part-60
13	Iron as Fe, mg/l	0.00	0.00	0.3	IS-3025/Part-53
14	Chromium as Cr, mg/l	0.00	0.00	0.05	IS-3025/Part-52
15	Zinc as Zn, mg/l	0.00	0.00	5.0	IS-3025/Part-49
16	Copper as Cu, mg/l	0.00	0.00	0.05	IS-3025/Part-42
17	Manganese as Mn, mg/l	0.00	0.00	0.1	IS-3025/Part-59
18	Boron as B, mg/l	0.00	0.00	0.5	IS-3025/Part-57
19	Residual Free Chlorine, mg/l	0.00	0.00	0.2	IS-3025/Part-26
20	Total Alkalinity as CaCO ₃ , mg/l	2	50	200	IS-3025/Part-23
21	Total Suspended Solids, mg/l	0.00	0.00	10	IS-3025/Part-16

MICROBIOLOGICAL TEST

01	Total Coli form, MPN / 100ml	NIL	Not Detectable	Not Detectable	IS-1622-1981
02	E. Coli, MPN /100ml	Absent	Not Detectable	Not Detectable	IS-1622-1981
Remarks : The given water sample Microbiologically Safe.					

REMARK: The given sample above parameters are tested as per IS 10500 -2012 and it is Physical, Chemical Test. The water confirms RO – Limits, The water is safe for drinking.


Tested By

For ENDEAVOUR ACADEMY
Secretary

***** End of the Report *****

Principal

Authorized Signature



Note 1. The Results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be store for a period of 15 days unless otherwise specified. 3. This report is not to be reproduced, either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified.

Bangalore - 560 105. Tel : 080-29795002