



GLOBAL ANALYTICAL LABORATORY

ISO 9001:2015

#33/2, Shop No.13, C R S Building, C Ramalah Layout, Ramachandrapura Main Road,
Vidyaranyapura, Bangalore - 560 097. Mob: 9686489581, 9353921722
E-mail: globaltestinglab2020@gmail.com



PHYSICAL & CHEMICAL ANALYSIS REPORT

Report No: GAL/12/6163	Report Date: 05.12.2025
Name : M/S ENDEAVOUR ACADAMY	Sample Collected On: 01.12.2025
Address: # 41, BUKKASAGARA VILLAGE , JIGANI HOBLI	Sample Tested On: 01.12.2025
ANEKAL TALUK, BENGALURU - 560105	Sample Particulars: RO - WATER

The water sample submitted by client and analyzed by us with the following results:

SAMPLE DESCRIPTION: Colorless, Odorless, and Transparent Liquid

TESTS (As per IS 10500:2012)	RESULTS	Maximum RO - LIMITS (In mg/ L)	Maximum Acceptable Limits (In mg/L)	Protocol IS-3025	
1	Color, Hazen Units	<0.01	0.01	5	IS-3025/Part-4
2	Odor	Agreeable	Agreeable	Agreeable	IS-3025/Part-5
3	Turbidity, NTU	0.00	0.00	1	IS-3025/Part-10
4	PH Value	5.94	5.5 - 9	6.5 - 8.5	IS-3025/Part-11
5	Total Hardness as CaCO ₃ , mg/L	7	20	200	IS-3025/Part-21
6	Calcium as Ca, mg/L	2.83	6	75	IS-3025/Part-40
7	Magnesium as Mg, mg/L	0.69	1	30	IS-3025/Part-46
8	Chloride as Cl, mg/L	4.21	20	250	IS-3025/Part-32
9	Total Dissolved solids, mg/L	15	80	500	IS-3025/Part-16
10	Sulphate as SO ₄ , mg/L	0.00	0.00	200	IS-3025/Part-24
11	Nitrate as NO ₃ , mg/L	0.74	1	45	IS-3025/Part-34
12	Fluoride as F, mg/L	0.00	0.00	1.0	IS-3025/Part-60
13	Iron as Fe, mg/L	0.00	0.00	0.3	IS-3025/Part-53
14	Chromium as Cr, mg/L	0.00	0.00	0.05	IS-3025/Part-52
15	Zinc as Zn, mg/L	0.00	0.00	5.0	IS-3025/Part-49
16	Copper as Cu, mg/L	0.00	0.00	0.05	IS-3025/Part-42
17	Manganese as Mn, mg/L	0.00	0.00	0.1	IS-3025/Part-59
18	Boron as B, mg/L	0.00	0.00	0.5	IS-3025/Part-57
19	Residual Free Chlorine, mg/L	0.00	0.00	0.2	IS-3025/Part-26
20	Total Alkalinity as CaCO ₃ , mg/L	3.89	50	200	IS-3025/Part-23
21	Total Suspended Solids, mg/L	0.00	0.00	10	IS-3025/Part-16

MICROBIOLOGICAL TEST

01	Total Coli form, MPN / 100ml	NIL	Not Detectable	Not Detectable	IS-1622-1981
Remarks : The given water sample Microbiologically Safe.					

REMARK: The given sample above parameters are tested as per IS 10500 -2012 and it is Physical, Chemical Test. The water confirms IS - RO – Limits, Water is safe for Drinking.

***** End of the Report *****

Tested By

Authorized Signature

Note : 1. The Results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be store for a period of 15 days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified.